

CHAFFEE COUNTY BUILDING DEPARTMENT

P.O. BOX 699
SALIDA, COLORADO 81201

10066788

PHONE: (719) 539-2124

FAX: (719) 530-9208

Owner FASSTUN Date 5/14/19 Contractor _____

Location 11375 CR 251 A

Type of Inspection FINAL ROOF Approved Disapproved

Information or Corrections:

ALL COMPLETE

**AFTER CORRECTIONS ARE COMPLETE
PLEASE CALL FOR A REINSPECTION**

Time of Arrival _____ Time of Departure _____

Inspector [Signature]

CHAFFEE COUNTY BUILDING DEPARTMENT

P.O. BOX 699
SALIDA, COLORADO 81201

PHONE: (719) 539-2124

FAX: (719) 530-9208

Owner Fasching Date 5-9-19 Contractor _____

Location 11325 CR 251-A

Type of Inspection Midroof Approved Disapproved

Information or Corrections:

- One layer - overlay
- Nail pattern - OK
- Mid roof - OK
- OK to continue

**AFTER CORRECTIONS ARE COMPLETE
PLEASE CALL FOR A REINSPECTION**

Time of Arrival _____ Time of Departure _____

Inspector Chadley



Date Applied: 5-1-19 Permit # 10066788
 Permit Fee: 100.00 \$100.00 Minimum
 Valuation: \$ 6850.00
 Payment Method: OK 1385 Pd. By: Cont
 Approved By: Cheryl Clark

APPLICATION FOR ROOFING PERMIT
A SEPARATE PERMIT IS REQUIRED FOR EACH STRUCTURE

PROPERTY ADDRESS: 11325 C.R. 251A
 PROPERTY OWNER: JOHN FASCHING PHONE: 719 221 3275
 CONTRACTOR: MARK WILDMAN PHONE: 719 207 0012
 ADDRESS: 63788 E. RAA MOFFAT EMAIL: _____

If structure is located in a Historical District contact the municipality planning department for review.

SQUARE FOOTAGE AREA: 2700

TYPE OF WORK: Re-roof (existing structure) Roof repair
 Commercial Residential

IF RESIDENTIAL, PLEASE SPECIFY:
 Primary Residence ADU Detached Garage Shed
 Mobile Home Barn Other _____

EXISTING ROOF:
 Composition/ Asphalt Tile/ Slate Wood / Cedar Metal Built-up Membrane/ Liquid- applied

NEW ROOF:
 Composition/ Asphalt Tile/ Slate Wood / Cedar Metal Built-up Membrane/ Liquid- applied

TEAR OFF? Yes No
 If No, How Many Layers? 1

RE-USE FLASHING? Yes No

IS ANY PORTION OF THE ROOF LESS THAN 4:12?
 Yes No If Yes, please specify the pitch: _____

Double Underlayment Required? Yes No
 Lap Sealant Required? Yes No

CHANGING ROOF VENTILATION? Yes No
 If yes, please indicate: **EXISTING:** Turtle Soffit Ridge Gable Turbine Power **NONE**
NEW: Turtle Soffit Ridge Gable Turbine Power

I Have read the relevant adopted codes that pertain to this roofing installation and agree to perform this work in accordance with these and accepted methods of workmanship, in addition to product installation instructions. I understand it is my responsibility to notify the building department for mid-roof inspection & final inspection, when roof is complete.

Signature of applicant Mark A. Wildman

NOTE: ACCESS TO THE ROOF FOR INSPECTION IS THE RESPONSIBILITY OF THE APPLICANT. IF ACCESS IS NOT PROVIDED (LADDER, ETC) THE INSPECTION WILL BE DISAPPROVED.

This permit expires one year from the date of issuance. If a final inspection has not been requested and approved within this year, a new permit or extension will be required.



CHAFFEE COUNTY DEVELOPMENT SERVICES DEPARTMENT

Asphalt Shingle Roofing Checklist

- **Permit card must be posted at job site and be accessible for inspection signoff.** Failure to have permit card posted and accessible may result in disapproval of inspection and a re-inspection fee may be assessed.
- Access to the roof area for inspection is the responsibility of the permit holder. The ladder must be properly set and secured.
- **A mid roof or in progress inspection is required for all re-roof permits.** All ice/water barrier, roof underlayment, drip edge and required flashings must be completely installed. Shingles may be installed to verify proper installation procedures, i.e. nail pattern, shingle overhang, shingle layout, shingle exposure etc. **DO NOT** install shingles past ice/water barrier to allow for inspection of all underlayment.
- Underlayment application shall be per **2015 IRC R905.1.1 & Table R905.1.1(2)**.
- Two layers of ASTM D226 roofing felt (half lapped) or full ice/water barrier is required for roof slopes greater than 2/12 or less than 4/12 per 2015 IRC R905.1
- Ice/water barrier shall be installed per **2015 IRC R905.1.2.** (Minimum 24" inside exterior wall from the lowest point of the roof)
- Shingle attachment shall be per **2015 IRC R905.2.6** and the manufacturer. Use the high wind manufacturer nailing requirements for all of Chaffee County.
- Shingle layout, weather exposure and roof overhang shall be per manufacturer instructions.
- Roof valley flashing where required shall be per **2015 IRC R905.2.8.2.**
- Sidewall flashing where required shall be per **2015 IRC R905.2.8.3.**
- Drip edge shall be installed per **2015 IRC R905.2.8.5.**