

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

1318

WELL PERMIT NUMBER 28018 - A
DIV. 2 WD 11 DES. BASIN MD

APPLICANT

LAKE COUNTY MMI LLC
2801 S NEWLAND ST
DENVER, CO 80227-

APPROVED WELL LOCATION

LAKE COUNTY
SW 1/4 SW 1/4 Section 33
Township 9 S Range 80 W Sixth P.M.

DISTANCES FROM SECTION LINES

651 Ft. from South Section Line
247 Ft. from West Section Line

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: 383731 Northing: 4341751

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(c) for the relocation of an existing well, permit no. 28018. The old well must be plugged in accordance with Rule 16 of the Water Well Construction Rules within ninety (90) days of completion of the new well. The enclosed Well Abandonment Report form must be completed and submitted to affirm that the old well was plugged.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside one single family dwelling, the irrigation of not more than 1 acre of home gardens and lawns, and the watering of domestic animals. This well is to be located on a portion of the SW1/4, Section 33, T9S, R80W, Sixth P.M., Lake County.
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTICE: This permit has been approved subject to the following changes: The distances from section lines were calculated from UTM coordinate values provided with the permit application. You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.) CDK 3/24/05

APPROVED
CDK

Hal D. Simpson

State Engineer

Clay Kinnel

By

Receipt No. 0536663

DATE ISSUED 03-24-2005

EXPIRATION DATE 03-24-2007